



## ***APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER, RECYCLED WATER AND SEWER FACILITIES***

Please submit a completed Approved Materials List to the District's Share File site (all 11 pages). The Project Name should be listed at the top of each page. To obtain a link to the Share File site please contact the Engineering Department Assistant.

**PROJECT NAME:** \_\_\_\_\_

**Supplier Name:** \_\_\_\_\_

**Contact Person:** \_\_\_\_\_

**Phone:** \_\_\_\_\_

-----  
**FOR DISTRICT USE ONLY BELOW THIS LINE**

REVIEWED ONLY FOR GENERAL CONFORMITY TO PLANS AND STANDARD SPECIFICATIONS

- ☐ **APPROVED**
- ☐ **APPROVED AS NOTED**
- ☐ **MAKE CORRECTIONS NOTED & RESUBMIT**
- ☐ **REJECTED**

\_\_\_\_\_  
*Initials*

\_\_\_\_\_  
*Date*

**PROJECT #:**

\_\_\_\_\_

**EAM WO#:**

\_\_\_\_\_

*As-Built Stamp:*

**OLIVENHAIN MUNICIPAL WATER DISTRICT**  
**APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER,  
 RECYCLED WATER AND SEWER FACILITIES**

***\*All Material Being Used Shall Conform w/OMWD's Standard Specifications***

Project \_\_\_\_\_

**PLEASE INDICATE WHICH PRODUCT YOU ARE USING BY PLACING AN "X" ON THE  
 APPROPRIATE LINE TO THE RIGHT OF EACH MANUFACTURER**

Item	Description	Std Spec Section	Manufacturer
<b>AIR/VACUUM VALVE ENCLOSURE</b> <i>*must be accompanied by a shop drawing</i>	2 Piece Assembly with Bolt Down Base and Removable Cover, Polyethylene Material, Sandstone Color with Identification Band, OSHA Blue for WATER, OSHA Purple for Recycled Water 1424 for 1" 1830 for 2" 2436 for 3"	15092	VCAS-1424-SM w/tape & screen _____ VCAS-1830-SM w/tape & screen _____ VCAS-2436-SM w/tape & screen _____  <input type="checkbox"/> Potable <input type="checkbox"/> RCW
<b>ANGLE METER STOP, QUICK JOINT X METER NUT</b>	1" Bronze Angle Meter Stop (Ball Valve) with 90 Degree Lockwing, Inlet Quick Joint for Copper Water Tube x Meter Swivel Nut Outlet	15081	Ford BA43-444W-Q-NL _____ Jones - J1963WSG _____ McDonald 74602BQ _____ Mueller - B24258 _____
<b>ANGLE METER STOP, QUICK JOINT X METER FLANGE</b>	1-1/2", 2" Bronze Angle Meter Stop (Ball Valve) with 90 Degree Lockwing, Inlet Quick Joint for Copper Water Tube x Meter Flange Outlet	15081	Ford BFA43-777W-Q-NL _____ Jones - J1975WSG _____ McDonald 74602BQ _____ Mueller - B24276 _____
<b>ANGLE VALVE</b>	Bronze Angle Valve, 2" and Smaller 300 PSI Rated, Female Threaded Ends	15080	Nibco T-375-B _____ Jones J-380 _____
<b>ANGLE VALVE HYDRANT HEAD</b>	Bronze, Angle Design, 300 PSI Rated, 4" Inlet Female IPT, 2-1/2" Outlet National Standard Hose Thread, Cap and Chain	15080	Jones J-344HP _____
<b>ANODE, MAGNESIUM</b> <i>*must be accompanied by a shop drawing</i>	High or Standard Potential Anode with a Galvanized Steel Core Encased in a Square Magnesium Alloy Ingot Pre-Packaged in a Permeable Cotton Cloth Bag. Provide Ingot Weight as Specified on the Approved Plans	13110	Corrpro _____ Corrosion Control Products _____ Farwest _____ Calpico _____
<b>ANODE, ZINC</b>	Each Zinc Anode shall be Pre-Packaged in a Permeable Cloth Bag and shall Weigh 30 Pounds	13110	Corrpro _____ Corrosion Control Products _____ Farwest _____ Calpico _____

***Please Contact the District's Inspection Dept. for the material to be used if the  
 Part or Model numbers shown are no longer available.***

**OLIVENHAIN MUNICIPAL WATER DISTRICT**  
**APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER,  
 RECYCLED WATER AND SEWER FACILITIES**

***\*All Material Being Used Shall Conform w/OMWD's Standard Specifications***

Project \_\_\_\_\_

**PLEASE INDICATE WHICH PRODUCT YOU ARE USING BY PLACING AN "X" ON THE  
 APPROPRIATE LINE TO THE RIGHT OF EACH MANUFACTURER**

Item	Description	Std Spec Section	Manufacturer
<b>BACKFLOW PREVENTER</b> <i>*must be accompanied by a shop drawing</i>	Reduced Pressure Principal Type Assemblies as Approved by the State of California, Department of Health Services	15112	List of Approved Backflow Prevention Assemblies _____
<b>BOLT KIT, 316 SS</b> <i>*for specific uses only</i>	Hex-Head Machine, ASTM A193, Grade B 8M Bolts and ASTM A194, Grade 8M Nuts, Grade 8M Flat Washers Bolt Kit includes: Bolts, Nuts, and Flat Washers	15050	Tripac Fasteners _____ Pacific Coast Bolt _____ ITP, Inc. _____
<b>BOLT KIT</b>	Hex-Head Machine, Cadmium/Zinc Plated, ASTM A307, Grade B Bolts and A307 2H Heavy Hex Nuts Bolt Kit includes: Bolts, Nuts, and Flat Washers	15050	Tripac Fasteners _____ Pacific Coast Bolt _____ ITP, Inc. _____
<b>BURY ELBOW, DUCTILE IRON</b>	16" DI Long Radius Bury El, MJ or PO Holiday Free Epoxy Lined Bells	15109	Clow _____ Star _____ Sigma _____ South Bay Foundry _____
<b>CATHODIC TEST STATION BOX</b>	54 Lb Concrete Body with 12 Lb Ductile Iron Lid and Lid Ring. "CP TEST" shall be Cast into the Lid in 1" Letters. For Cathodic Protection Test Stations, Anode Ground Beds and Insulated Flange Test Stations	13110	Brooks 1 -RT _____ Farwest Type 1-RT _____ J&R 3RT _____
<b>CATHODIC WELDING</b>	For Welding Cathodic Bond Wires to Steel Pipelines	13110	Cadweld _____
<b>COATING, INTERNAL PIPE</b>	For Coating the Internal Pipe Lining for an Insulated Flange Kit	13110	Aquatapox CCI _____ Hydro-Pox _____
<b>CONNECTOR, TRACER WIRE SPlicing KIT</b>	All Brass Split Bolt to be Accompanied and Encased with Rubberized Tape, and then Electrical Tape	15292 15293	_____

***Please Contact the District's Inspection Dept. for the material to be used if the  
 Part or Model numbers shown are no longer available.***

**OLIVENHAIN MUNICIPAL WATER DISTRICT**  
**APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER,  
 RECYCLED WATER AND SEWER FACILITIES**

***\*All Material Being Used Shall Conform w/OMWD's Standard Specifications***

Project \_\_\_\_\_

**PLEASE INDICATE WHICH PRODUCT YOU ARE USING BY PLACING AN "X" ON THE  
 APPROPRIATE LINE TO THE RIGHT OF EACH MANUFACTURER**

Item	Description	Std Spec Section	Manufacturer
<b>CORPORATION STOP, MIPT X QUICK JOINT</b>	Bronze Ball Valve, Male Iron Pipe Thread x Quick Joint (T-Head Only), 1", 1-1/2" and 2" Full Opening 1"            1-1/2"            2" <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15080	Ford FB1100-x-Q-NL _____ MCD 74704BQ _____ Mueller - B25028 _____ Jones - J1935 SG _____
<b>COUPLING, C900 PVC, HIGH DEFLECTION</b>	4" through 12" Solid PVC for Obtaining Deflection Only. Provides 4 Degree Maximum Deflection 4"       6"       8"       10"       12" <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15292	CertainTeed _____
<b>COUPLING, C900 PVC, CLOSURE / REPAIR</b>	4" through 12" Solid PVC for Closure or Repair 4"       6"       8"       10"       12" <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15292	CertainTeed _____
<b>COUPLING, C905 PVC, HIGH DEFLECTION</b>	4" through 12" Solid PVC for Obtaining Deflection Only. Provides 4 Degree Maximum Deflection 14"    16"    18"    20"    24" <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15293	Specified _____
<b>COUPLING, MECHANICAL CLAMP-TYPE</b> <i>*must be accompanied by a shop drawing</i>	Use for Above Ground DI or Steel Pipe 4" or Larger	15061 15240 15251	Grinnell #7001 _____ Tyler 500 _____ Victaulic #44, #77 _____
<b>COUPLING, STRAIGHT FLEXIBLE</b> <i>*must be accompanied by a shop drawing</i>	4" and Larger, Steel or Ductile Iron Construction, Slip x Slip, Epoxy Coated with 304 or 316 Stainless Steel Bolts and Nuts. For Use on AC, PVC, DI, or Steel Pipe Must be Restrained When Used with AC Pipe Indicate Size _____	15122	APAC 301 _____ Ford FC1 _____ Powerseal 3501 _____ Romac 501 _____ Smith-Blair 411 _____

***Please Contact the District's Inspection Dept. for the material to be used if the  
 Part or Model numbers shown are no longer available.***

**OLIVENHAIN MUNICIPAL WATER DISTRICT**  
**APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER,  
 RECYCLED WATER AND SEWER FACILITIES**

***\*All Material Being Used Shall Conform w/OMWD's Standard Specifications***

Project \_\_\_\_\_

**PLEASE INDICATE WHICH PRODUCT YOU ARE USING BY PLACING AN "X" ON THE  
 APPROPRIATE LINE TO THE RIGHT OF EACH MANUFACTURER**

Item	Description	Std Spec Section	Manufacturer
<b>COUPLING, TRANSITION FLEXIBLE</b> <i>*must be accompanied by a shop drawing</i>	4" and Larger, Steel or Ductile Iron Construction, Holiday Free Epoxy Coated with 304 or 316 SS Bolts and Nuts. For use on AC, PVC, DI, or Steel Pipe. Must be Restrained When Used with AC Pipe Indicate Size _____	15122	APAC 311, 313 _____ Ford FC2A _____ Powerseal 3501, 3506 _____ Romac XR501 _____ Smith-Blair 413 _____
<b>DISMANTLING JOINT</b> <i>*must be accompanied by a shop drawing</i>	Telescoping, Adjustable, Double Flanged Fitting, with High Tensile Strength Zinc Plated Tie Bars. NSF-61 Epoxy or Nylon Interior and Exterior Coating		Romac Flexijoint _____ Star - StarFlex _____
<b>FIRE HYDRANT, BREAK-OFF RISERS</b>	Cast Iron 12" through 18" Long with Machined V-Groove 4" from One End, Groove to be 1/8" to 3/16" Deep and 1/4" Wide	15109 15090	South Bay Foundry _____ Clow _____ Sigma _____ Star _____
<b>FIRE HYDRANT Up To 200 PSI</b>	6" High Pressure 200 PSI Wet Barrel, Bronze Fire Hydrant, with Six-Hole Bolt Pattern	15109	Clow 2060, 2065 _____ Jones J3765, J3775 _____ American AVK 2464X, 2468X _____
<b>FITTING, DUCTILE IRON, 4"</b>	Flanged, Push On, Tees, Bends, Crosses, Reducers, Adapters, etc. For 4", Per AWWA C110, C111, C153 and OMWD Standards. Holiday Free Epoxy Lined Bells 11 1/4   22 1/2   45   90   Tee   End Cap <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15240 15292 15293	Bachman _____ Sigma _____ Star _____ Tyler _____ US Pipe _____
<b>FITTING, DUCTILE IRON, 6"</b>	Flanged, Push On, Tees, Bends, Crosses, Reducers, Adapters, etc. For 6", Per AWWA C110, C111, C153 and OMWD Standards. Holiday Free Epoxy Lined Bells 11 1/4   22 1/2   45   90   Tee   End Cap <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15240 15292 15293	Bachman _____ Sigma _____ Star _____ Tyler _____ US Pipe _____

***Please Contact the District's Inspection Dept. for the material to be used if the  
 Part or Model numbers shown are no longer available.***

**OLIVENHAIN MUNICIPAL WATER DISTRICT**  
**APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER,  
 RECYCLED WATER AND SEWER FACILITIES**

***\*All Material Being Used Shall Conform w/OMWD's Standard Specifications***

Project \_\_\_\_\_

**PLEASE INDICATE WHICH PRODUCT YOU ARE USING BY PLACING AN "X" ON THE  
 APPROPRIATE LINE TO THE RIGHT OF EACH MANUFACTURER**

Item	Description	Std Spec Section	Manufacturer
<b>FITTING, DUCTILE IRON, 8"</b>	Flanged, Push On, Tees, Bends, Crosses, Reducers, Adapters, etc. For 8", Per AWWA C110, C111, C153 and OMWD Standards. Holiday Free Epoxy Lined Bells 11 1/4    22 1/2    45    90    Tee    End Cap <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15240	Bachman _____
		15292	Sigma _____
		15293	Star _____
			Tyler _____
			US Pipe _____
<b>FITTING, DUCTILE IRON, 10"</b>	Flanged, Push On, Tees, Bends, Crosses, Reducers, Adapters, etc. For 10", Per AWWA C110, C111, C153 and OMWD Standards. Holiday Free Epoxy Lined Bells 11-1/4    22-1/2    45    90    Tee    End Cap <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15240	Bachman _____
		15292	Sigma _____
		15293	Star _____
			Tyler _____
			US Pipe _____
<b>FITTING, DUCTILE IRON, 12"</b>	Flanged, Push On, Tees, Bends, Crosses, Reducers, Adapters, etc. For 12", Per AWWA C110, C111, C153 and OMWD Standards. Holiday Free Epoxy Lined Bells 11-1/4    22-1/2    45    90    Tee    End Cap <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15240	Bachman _____
		15292	Sigma _____
		15293	Star _____
			Tyler _____
			US Pipe _____
<b>FLANGE COUPLING ADAPTER</b>	6" and Larger, Mechanical x Flange. Steel or Ductile Iron without Anchor Pins, Holiday Free Epoxy Coated, 304 SS Bolts and Nuts.	15122	Dresser 127, 128 _____
			Ford FFCA Style _____
			Baker 601, 602 _____
			Powerseal 3521, 3526 _____
			Romac FCA501, FC400 _____
			Smith-Blair 912, 913 _____
<b>GASKET, PAPER</b>	1/8" Thick Full Face or Ring, Aramid Fiber Bound with Nitrile. No Asbestos Content Ring                      Full Face <input type="checkbox"/> <input type="checkbox"/>	15050	Garlock Bluegard _____
			Klinger C4400 _____
			Tripac 5000 _____
			Calpico _____

***Please Contact the District's Inspection Dept. for the material to be used if the  
 Part or Model numbers shown are no longer available.***

**OLIVENHAIN MUNICIPAL WATER DISTRICT**  
**APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER,  
 RECYCLED WATER AND SEWER FACILITIES**

***\*All Material Being Used Shall Conform w/OMWD's Standard Specifications***

Project \_\_\_\_\_

**PLEASE INDICATE WHICH PRODUCT YOU ARE USING BY PLACING AN "X" ON THE  
 APPROPRIATE LINE TO THE RIGHT OF EACH MANUFACTURER**

Item	Description	Std Spec Section	Manufacturer
<b>GROUT</b>	Non-Shrink Cement Based Construction Grout for Crack Repair, Flooring Mortar, Dowel Grouting, Crack Sealing and General Binding	03000	UPCON High Flow _____ Master Flow 713 _____
<b>INSULATING BLANKET</b> <i>*must be accompanied by a shop drawing</i>	Insulating Blanket for Corrosion Interference Mitigation	13110	
<b>INSULATING COUPLINGS</b> <i>*must be accompanied by a shop drawing</i>	Insulating Couplings for Corrosion Protection of Pipelines/Appurtenances 1"      1 1/2"      2"      3" <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15080	Wilkins Model DUXL _____ Watts Model LF3003 _____
<b>INSULATING FLANGE KIT</b>	Insulating Flange Kits for Corrosion Protection of Pipelines/Appurtenances	13110	Advance Product Systems _____ Calpico _____ Corpro _____ Farwest _____
<b>JOINT RESTRAINT ASSEMBLY</b>	360 Degree Wedge Type Restraint System for Ductile Iron and C900 PVC, Sizes 6" Through 24"	15240 15292	Ford Uniflange 1300 Series _____ Ford Uniflange 1500 Series _____ EBAA Iron _____ Sigma PV-LOK _____ Romac DI - Roma Grip _____ Romac 600 Series _____
<b>MARKING TAPE</b>	6" wide, Warning/Identification (Metallic) Marking Tape for Buried Facilities POT      RCW      S      FM      ELEC      FIBER <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15061 15240 15292 15293	Linetec _____ Terra Tape _____ Calpico _____ Christy _____

***Please Contact the District's Inspection Dept. for the material to be used if the  
 Part or Model numbers shown are no longer available.***

**OLIVENHAIN MUNICIPAL WATER DISTRICT**  
**APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER,  
 RECYCLED WATER AND SEWER FACILITIES**

***\*All Material Being Used Shall Conform w/OMWD's Standard Specifications***

Project \_\_\_\_\_

**PLEASE INDICATE WHICH PRODUCT YOU ARE USING BY PLACING AN "X" ON THE  
 APPROPRIATE LINE TO THE RIGHT OF EACH MANUFACTURER**

Item	Description	Std Spec Section	Manufacturer
<b>METER BOX</b> <b>*must be accompanied by a shop drawing</b>	17"x28" Precast Meter Box and 2 Piece Polymer Concrete Cover with Reading Lid for 1" Water Service, Use Purple Covers for Recycled Water, For Water Service Installation, Polymer Concrete Cover Shall Have Hole for Touch Read Device. MAR and Blowoff Installation Does Not Require Hole Cut Out WS      MAR/BO <input type="checkbox"/> <input type="checkbox"/>	15081	J&R Concrete Products, Inc. _____
		15090	Armor Cast _____
		15091	Old Castle _____
<b>METER BOX</b> <b>*must be accompanied by a shop drawing</b>	24"x36" Precast Meter Box and 2 Piece Polymer Concrete Cover with Reading Lid for 1" Water Service, Use Purple Covers for Recycled Water For Water Service Installation, Polymer Concrete Cover Shall Have Hole for Touch Read Device MAR and Blowoff Installation Does Not Require Hole Cut Out WS      MAR/BO <input type="checkbox"/> <input type="checkbox"/>	15081	J&R Concrete Products, Inc. _____
			Armor Cast _____
			Old Castle _____
<b>OUTLET, WELD-ON</b> <b>*must be accompanied by a shop drawing</b>	Weld-On Outlet with Reinforcing Collar or Wrapper for Connection to CML&C Steel Pipe	15080	Pipeline Products _____
<b>PIPE, COPPER WATER TUBE</b>	Type K Soft Seamless Rolled Tubing, Type K Soft Seamless Straight Lengths, Type K Hard Seamless Straight Lengths (Soft - Buried Application ONLY) (Hard - Above Ground ONLY) Soft      Hard      1"      1-1/2"      2"      3" <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15220	Cerro _____
			Mueller _____
			Cambridge-Lee _____

***Please Contact the District's Inspection Dept. for the material to be used if the  
 Part or Model numbers shown are no longer available.***



**OLIVENHAIN MUNICIPAL WATER DISTRICT**  
**APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER,  
 RECYCLED WATER AND SEWER FACILITIES**

***\*All Material Being Used Shall Conform w/OMWD's Standard Specifications***

Project \_\_\_\_\_

**PLEASE INDICATE WHICH PRODUCT YOU ARE USING BY PLACING AN "X" ON THE  
 APPROPRIATE LINE TO THE RIGHT OF EACH MANUFACTURER**

Item	Description	Std Spec Section	Manufacturer
<b>PIPE, DUCTILE IRON</b> <i>*must be accompanied by a shop drawing and lay sheets</i>	For Water Lines 4" and Larger Manufactured per AWWA C151	15240	American Pipe _____ Griffin _____ Pacific States _____ U.S. Pipe _____
<b>PIPE, PVC C900</b>	For Water Lines 4" through 12" Manufactured per AWWA C900 in Class 150 and 200 DR14      DR18 4"      6"      8"      10"      12" <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15292	Diamond Plastics _____ VinylTech _____ North American Pipe _____ JM Eagle _____
<b>PIPE, PVC C905</b>	For Water Lines 14" through 24" Manufactured per AWWA C905 14"      16"      18"      20"      24" <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15293	Diamond Plastics _____ VinylTech _____ North American Pipe _____ JM Eagle _____
<b>PLASTIC POLYETHYLENE ENCASEMENT</b>	8-MIL Thick Polyethylene Encasement Tube for Ductile Iron Pipe, CML&C.	09954	
<b>PLASTIC WRAPPER</b>	Clear Plastic Wrapper over Wax Tape Coating and Primer in Underground Applications	09952	Denso Tape PVC Self-Adhesive _____ Trenton Poly-Ply _____
<b>POLYETHYLENE WRAP</b>	8-MIL Thick Polyethylene Encasement Sheet for Buried Fittings and Valves. Purple Color for Recycled Water	09954	
<b>SERVICE SADDLE FOR ACP, DIP, AND PVC PRESSURE PIPE</b>	Cast Bronze Body with Stainless Steel Double Band Straps or Single Wide Strap with 4 Bolts, IP Outlet Sizes ACP      DIP      PVC <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> 1"      1-1/2"      2" <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	15080	Ford - 202BS _____ Romac - 202BS _____ McDonald - 3846 _____ Jones - J-969 _____

***Please Contact the District's Inspection Dept. for the material to be used if the  
 Part or Model numbers shown are no longer available.***

**OLIVENHAIN MUNICIPAL WATER DISTRICT**  
**APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER,  
 RECYCLED WATER AND SEWER FACILITIES**

***\*All Material Being Used Shall Conform w/OMWD's Standard Specifications***

Project \_\_\_\_\_

**PLEASE INDICATE WHICH PRODUCT YOU ARE USING BY PLACING AN "X" ON THE  
 APPROPRIATE LINE TO THE RIGHT OF EACH MANUFACTURER**

Item	Description	Std Spec Section	Manufacturer
<b>TAPE, PLASTIC ADHESIVE</b>	10 to 50 MIL x 2" Wide General Utility Tape for Corrosion Protection of Above and Below Ground Pipes and Fittings	09954 09952	Calpico Vinyl Tape _____
			Christy _____
			Northtown _____
			Polyken - 900 _____
			Scotchwrap - 50 _____
<b>TAPPING SLEEVE FOR ACP, DI, AND PVC PIPE</b>	Fabricated Stainless Steel Tapping Sleeve with Stainless Steel Bolts and Nuts	15080	Ford - FTSS _____
			PowerSeal - 3460AS _____
			Romac - SSTIII _____
			Smith Blair - 665 _____
<b>THREDOLET</b>	Forged Steel Fitting ASTM A105. 3000#, NPT Threads	15061	Bonney Forge _____
			Allied Piping Products _____
			Pipeline Products _____
<b>TRACER WIRE</b>	AWG No. 8 Stranded Copper Wire with High Molecular Weight Polyethylene (HMW/PE) Insulation Specifically Designed for Direct Burial in Corrosive Soil or Water	15292	Calpico - HMW/PE #8 _____
		15293	Farwest - HMW/PE #8 _____
			KALAS - w-08hmwpe-str _____
<b>VALVE BOX AND COVERS, MANUAL AIR RELEASE AND BLOW-OFF ASSEMBLIES</b> <i>*must be accompanied by a shop drawing</i>	Cast Iron Frame and Lid and 12" Pipe Sleeve. Cast on the Lid the Words "OMWD", and "WATER" or "RW" (For Street Use Only)	15092	South Bay Foundry - SBF 1243 _____
<b>VALVE BOX AND COVERS, GATE VALVE</b>	Cast Iron Frame and Cover and Extension Pipe. Cast on the Cover the Words "OMWD", and "WATER" or "RW"	15101	South Bay Foundry - SBF 1208-N _____

***Please Contact the District's Inspection Dept. for the material to be used if the  
 Part or Model numbers shown are no longer available.***

**OLIVENHAIN MUNICIPAL WATER DISTRICT**  
**APPROVED MATERIALS LIST FOR CONSTRUCTION OF POTABLE WATER,  
 RECYCLED WATER AND SEWER FACILITIES**

***\*All Material Being Used Shall Conform w/OMWD's Standard Specifications***

Project \_\_\_\_\_

**PLEASE INDICATE WHICH PRODUCT YOU ARE USING BY PLACING AN "X" ON THE  
 APPROPRIATE LINE TO THE RIGHT OF EACH MANUFACTURER**

Item	Description	Std Spec Section	Manufacturer
<b>VALVE, COMBINATION AIR RELEASE &amp; AIR/VACUUM, 3" AND SMALLER</b>	Single Chamber, HDPE Control Floats, Stainless Steel Body, 1/4" NPT Test/Bleed Cock	15108	Vent-O-Mat DN25 RBX 2521 _____ Vent-O-Mat DN50 RBX 4021 _____ Vent-O-Mat DN80 RBX 1631 _____ Vent-O-Mat DN100 RBX 2531 _____
<b>VALVE, GATE, RESILIENT SEATED</b> <i>*must be accompanied by a shop drawing</i>	3" through 24" Resilient Seated, Non-Rising Stem, Counter-Clockwise Opening, Type 304 or 316 SS Body Bolts, 250 PSI Working Pressure, Holiday Free Interior Lining	15101	AVK or Approved Equal _____
<b>WAX TAPE COATING</b>	4 Part, Cold Applied Wax Tape Coating System for Buried Piping Components System Includes: Primer, Wax Tape, Clear Wrap, 10 MIL Tape, and 8 MIL Thick Polyethelene Sheet	09952	Denso Densyl Tape _____ Trenton No.1 Wax Tape _____

***Please Contact the District's Inspection Dept. for the material to be used if the  
 Part or Model numbers shown are no longer available.***