



**ADDENDUM NO. 1  
TO THE  
PRELIMINARY AND FINAL DESIGN OF HEADWORKS  
SCREENING SYSTEM IMPROVEMENTS**

**Request for Proposals**

November 16, 2020

The following addendum shall be made part of the Request for Proposal. **The deadline for submitting proposals has been CHANGED to 2:00 pm Tuesday December 1, 2020 at 1966 Olivenhain Road, Encinitas, CA 92024.**

**ADDENDUM SECTION 1 – PRE-PROPOSAL QUESTIONS**

**Q:** What instrumentation does the District prefer and will the District perform their own telemetry programming?

**A:** The District prefers Allen-Bradley PLC's. Consultant shall confirm compatibility/integration of the Parkson Aqua Guard UltraClean system with Allen Bradley PLC's and provide the District with options/cost estimates. The District does not perform telemetry programming in-house. This shall be provided by the Consultant as outlined in the RFP.

**ADDENDUM SECTION 2 – CHANGES TO THE REQUEST FOR PROPOSAL**

**DELETION OF WESTECH CLEANFLO MONOSCREEN**

The District has been made aware of and verified that WesTech will no longer be manufacturing the CleanFlo Monoscreen after 2020. Consequently, the District is removing the CleanFlo Monoscreen from any further evaluation and eliminating it from this scope of services. Evaluation of the headworks equipment identified in Task 1.2 – Prepare Preliminary Design Report in the RFP should now be limited to the Parkson Corporation Aqua Guard, which is now to be considered the Recommended Equipment. No further evaluation of the WesTech CleanFlo Monoscreen is required.


**ADDENDUM SECTION 3- CHANGES TO THE DUE DATES**

- The last day for questions has been CHANGED to Friday November 20, 2020 5PM
- The proposal due date has been CHANGED to Tuesday December 1, 2020 2PM

**END OF ADDENDUM NO. 1**

APPROVED:

**OLIVENHAIN MUNICIPAL WATER DISTRICT**

  
\_\_\_\_\_  
Jason P. Hubbard, P.E.  
Engineering Manager