



**ADDENDUM NO. 1  
TO THE  
REQUEST FOR PROPOSALS FOR DRONE INSPECTION SERVICES**

**September 3, 2020**

The following addendum shall be made part of the Request for Proposals:

**ADDENDUM SECTION 1 – Request for Proposals**

REQUEST FOR PROPOSALS, COVER SHEET: **CHANGE** Proposals Due September 17, 2020 2:00 P.M. to **Proposals due September 24, 2020 2:00 P.M.**

REQUEST FOR PROPOSALS, PAGE 8, SECTION 10 SUBMITTAL REQUIREMENTS: **CHANGE** Proposals must be received no later than 2:00 P.M. PST on September 17, 2020 2:00 P.M. to Proposals must be received no later than **2:00 P.M. PST September 24, 2020.**

REQUEST FOR PROPOSALS, PAGE 9, SECTION 14 SCHEDULE: **CHANGE** Proposals Due September 17, 2020, 2:00 PM to Proposals Due September 24, 2020, 2:00 PM

REQUEST FOR PROPOSALS, PAGE 10, SECTION 15 SPECIAL CONDITIONS: **CHANGE** Proposals are due September 17, 2020 at 2:00 pm to Proposals are due September 24, 2020 at 2:00 pm.

ATTACHMENT, EXHIBIT 1, DRONE INSPECTION SITE LIST: **REMOVE** Drone Inspection Site List **REPLACE** with Drone Inspection Site List Revised.

**END OF ADDENDUM NO.1**

Attachments:

Drone Inspection Site List Revised

APPROVED:  
OLIVENHAIN MUNICIPAL WATER DISTRICT

  
\_\_\_\_\_  
Jason P. Hubbard, P.E.  
Engineering Manager

September 3, 2020  
RFP Drone Inspection Services

ADDENDUM NO. 1

DRONE INSPECTION SITE LIST REVISED

SITE #	ABOVE GROUND PIPELINES	PIPE SIZE/MATERIAL	PIPELINE TYPE/SUPPORTS	EASEMENT TYPE	EASEMENT NUMBER	EASEMENT WIDTH (FEET)	JURISDICTION	LENGTH OF PIPELINE OR EASEMENT TO BE ASSESSED (FEET)	LATITUDE/LONGITUDE	NOTES	
1	9556 Del Dios Hwy	6" STEEL	WATER MAIN - PIPE SUPPORTS	OMWD	32	20	COUNTY OF SAN DIEGO	105	33.06145 -117.127476	12/5/16 - Portion of above ground PL 50-60' from residence. Small crack in exterior concrete mortar lining (12" length). Consider relocating line into Mt. Israel Rd and relocating existing services. Reinspect 2020	
2	Calle Barcelona	12" STEEL	RECYCLED WATER MAIN - BRIDGE MOUNTED	ROAD ROW	N/A	95	CITY OF CARLSBAD	115	33.072904 117.263889	11/16/16 - Minor discoloration & corrosion of pipeline. The PL has Victaulic grooved couplings. Recommendations to replace nylon bushing, trim trees, install RCW markings on PL, repaint PL. Reinspect 2020	
3	Calle Ponte Bella	12" STEEL	WATER MAIN - BRIDGE MOUNTED	ROAD ROW	N/A	40	COUNTY OF SAN DIEGO	380	33.054904 117.197105	11/1/16 - Joints & pipeline appear in good condition. Pipe support south end needs adjusted. Couplings on either end of bridge have minor corrosion. Reinspect 2020.	
4	Camino Santa Fe	12" STEEL	WATER MAIN - PIPE SUPPORTS	OMWD	48	20	COUNTY OF SAN DIEGO	760	33.029391 -117.133447	11/22/16 - Access to entire above ground pipeline difficult due to terrain & heavy brush. Leak detected & repaired by OPs. Reinspect 2018	
5	El Camino Del Norte	6" DIP in 12" STEEL SLEEVE	<b>NOT IN THIS CONTRACT</b>							N/A	12/13/16 - Waterline encased in concrete, so cannot be inspected. Concrete appears to be in good condition. Reinspect 2020
6	Levante Street	10" STEEL	WATER MAIN - BRIDGE MOUNTED	ROAD ROW	N/A	68	CITY OF CARLSBAD	130	33.078087 117.266703	11/16/16 - Minor exterior corrosion. Some pipe rollers loose, but most likely OK. Reinspect 2020	
7	Wildflower Estates	14" STEEL	TRANSMISSION MAIN - PIPE SUPPORTS	OMWD	33	20	COUNTY OF SAN DIEGO	115	33.053496 -117.204260	11/23/16 - Pipe and concrete piers appear to be in good condition. Reinspect 2020	

**EASEMENTS**

8	Rancho Santa Fe Road to Denk Reservoir	18" CML 16" STEEL 30" CML	TRANSMISSION MAIN	OMWD	521 1283	40	CITY OF CARLSBAD	1400	33.089257 -117.223414	7/29/20 - Received photo of easement from Jose Rodriguez for request to clear
9	Artesian Trail (Gano Reservoir) to Lusardi Creek	24" STEEL	TRANSMISSION MAIN	OMWD	1128, 1597, 1226 1228, 1225, 1224 1222	30	COUNTY OF SAN DIEGO	2100	33.010897 -117.157160	7/29/20 - Received photo of easement from Jose Rodriguez for request to clear
10	Unit G Pipeline - Bridoon Terrace to Rancho Summit Drive	21" STEEL 18" CML	TRANSMISSION MAIN	OMWD	173, 179, 529	30	CITY OF ENCINITAS	2950	33.075097 -117.201233	7/29/20 - Received photo of easement from Jose Rodriguez for request to clear