

ADDENDUM NO. 1 TO THE

OMWD AC AND CONCRETE PAVING MAINTENANCE AND SWPPP DRAINAGE IMPROVEMENT PROJCT FOR THE OLIVENHAIN MUNICIPAL WATER DISTRICT

February 8, 2023

The following addendum shall be made part of the Bidding Opportunity. The deadline for submitting pre-bid questions in writing has been extended to Monday, February 13, 2023 at 2:00 p.m. The deadline for submitting bid has not changed and remains at 2:00 p.m. Thursday February 23, 2023 at 1966 Olivenhain Road, Encinitas, CA 92024.

ADDENDUM SECTION 1 – QUESTIONS

- 1. Q: What is the Engineer's Cost Estimate?
 - A: The Engineer's Cost Estimate for all schedules is \$135,000. See revised Project at a Glance.
- 2. Q: Are contractors allowed to visit the project site prior to bidding?
 - A: Potential bidders in attendance of the mandatory pre-bid may request site access. Contractors can reach out to OMWD staff by emailing prebid@olivenhain.com to request site access. The deadline to request a site visit is Friday, February 17, 2023 at 2pm. The last day to complete a site visit is Wednesday February 22, 2023.
- 3. Q: Can you please confirm intent is to slurry seal both new and existing asphalt.
 - A: Confirmed. New and existing shall both receive slurry seal as shown on revised Exhibit 2 and Exhibit 3.
- 4. Q: Please clarify curb style for concrete pad at Heavy Equipment Yard and provide detail.
 - A: Provide concrete pad with monolithic concrete curb with thickened edge and reinforcement, per updated Exhibit 4 and Exhibit 6.
- 5. Q: For the Upper Parking Lot, please clarify extent of walkway demo and clarify dimensions of new walkway and curb.
 - A: Demo approximately 20 ft of the existing 30-inch wide walkway back to existing control joint. Provide new concrete walkway and curb. See updated Exhibit 2 and New Exhibit 7, Detail 1.
- 6. Q: Will the deadline for questions be extended?
 - A: Yes, the deadline to submit pre-bid questions in writing has been extended to Monday, February 13, 2023 at 2 pm. The deadline for submitting bid has not changed and remains at 2:00 pm on Thursday, February 23, 2023.

February 8, 2023 ADDENDUM NO. 1

ADDENDUM DRAWING REVISIONS

- DELETE old Exhibit 2 Upper Parking Lot REPLACE Exhibit 2 – Upper Parking Lot – Rev. 1
- 2. **DELETE** old Exhibit 4 Heavy Equipment Yard **REPLACE** Exhibit 4 Heavy Equipment Yard Rev. 1
- 3. **UPDATE** Exhibit 6 Details; **ADD** Detail 6 Monolithic Curb
- 4. ADD Exhibit 7 Details II

END OF ADDENDUM NO. 1

Attachments:

Pre-Bid Agenda and attachments (Site Map and Project at a Glance)

02/08/2023

- Pre-Bid Sign- In Sheet
- Exhibit 2 Upper Parking Lot Rev 1
- Exhibit 4 Heavy Equipment Yard Rev 1
- Exhibit 6 Details
- Exhibit 7 Details II

APPROVED:

OLIVENHAIN MUNICIPAL WATER DISTRICT

Lindsey Stephenson, P.E.

Engineering Manager

February 8, 2023 ADDENDUM NO. 1



Olivenhain Municipal Water District (OMWD)

AC and Concrete Paving Maintenance & SWPPP Drainage Improvement Project

Pre-Bid Meeting Agenda

Date and Time:

Thursday February 2, 2023 at 10:00 AM

Location:

OMWD Headquarters: 1966 Olivenhain Rd, Encinitas, CA 92024

Attendees:

Steve Weddle, Engineering Services Supervisor, OMWD Andrea Scott, Engineering Technician III, OMWD Diana Spencer, Engineering Department Assistant, OMWD Marvin Cohen, Facilities Coordinator, OMWD

1. INTRODUCTIONS & SIGN-IN

Sign-in sheet is attached and will be distributed via email with the meeting minutes

2. THE WORK

- The Work for this project will consist of:
 - o Asphalt patching, crack fill and slurry of existing asphalt concrete parking lots
 - New concrete pad and asphalt concrete approach within the Heavy Equipment Yard
 - o All other work in accordance with the Contract Documents

3. BIDS DUE

- Bids must be stamped as received by OMWD staff before **2:00 PM on Thursday February 23, 2023** at OMWD Headquarters, 1966 Olivenhain Road, Encinitas, CA 92024.
- In-Person and Mailed Sealed bids are acceptable.
 - Tracking number must be provided for mailed bids.
 - Weather the Bidder submits by mail or in-person, it is the sole responsibility of the bidder to see that his/her bid is received as specified.
- The bid package shall include the following completed documents:
 - Provide a copy of the Bid Form Checklist (located in contract documents) with all required attachments.
 - o Provide one (1) executed original, clearly marked on the cover and acknowledge all addenda.
 - The entire set of Contract Documents is **NOT** required to be submitted for the contractor to be considered responsive.
 - Bids and/or modifications thereto received subsequent to the hour and date specified herein will not be considered.

4. KEY DATES

- Pre-Bid Questions due to prebid@olivenhain.com no later than 5:00 PM on February 10, 2023.
- Consideration of award of contract at the regularly scheduled Board of Directors meeting on March 15, 2023.
- If awarded, the Notice to Proceed (NTP) will be issued once the contract documents are fully executed.
 - Time is of the essence.

5. BIDDING INFORMATION

- Contractor shall be registered with the California Department of Industrial Relations (DIR) and shall have a valid California Contractor's license.
 - A General Engineering.
- Contractor must maintain and provide Certificates of general liability insurance, auto liability insurance, and workers compensation insurance to do business in the State of California.
- California Prevailing wage rates apply, and certified payroll records shall be provided to OMWD with each monthly billing.
- The bidding documents are posted on OMWD's website at www.olivenhain.com.
 - Select the "Construction Projects" Tab, choose the "Upcoming Projects and Planning Resources" section and scroll down to "Capital Improvement Projects - Bidding Opportunities" to access the document links.

6. BID SCHEDULE

- There are two (2) Bid Schedules (A & B)
 - Schedule A Basis for award
 - Schedule B Additive Alternative bid schedule
- Construction schedule is ONE-HUNDRED TWENTY (120) consecutive calendar days from issuing NTP.
- Acknowledgement of Addenda is mandatory

7. ADDITIONAL ITEMS TO CONSIDER

- Hours of Work Monday through Friday 8:00 AM to 4:30 PM (Full Owner Occupancy)
 - Absolutely no equipment shall be started or warmed up prior to 8:00 AM or after 4:30 PM
 - Saturday, Sunday, and nighttime work requires prior written approval by OMWD
 - No work on OMWD recognized holidays
 - No work that interferes with normal scheduled business, including District Board and Safety Meetings
- Contractor shall coordinate with District personnel prior to construction for Photo documentation of pre-existing conditions.
- Sequence of Work
 - Construction shall be phased to maintain site access and employee and customer parking. The Work shall be completed in 3 phases.
 - Upper Parking Lot
 - Lower Parking Lot
 - Heavy Equipment Yard
- Two-year guarantee
- Liquidated Damages- \$1500/day beyond contract

OMWD AC and Concrete Paving Maintenance & SWPPP Drainage Improvement Project Pre-Bid Meeting Agenda

8. OMWD CONTACT INFORMATION

• Pre-Bid Questions to: prebid@olivenhain.com

9. OPEN AGENDA

Overall Site Map





Project at a Glance

Mandatory Pre-Bid Meeting Date	Thursday, February 2, 2023 at 10:00 a.m. Meet at OMWD Headquarters: 1966 Olivenhain Rd, Encinitas, CA 92024
Pre-Bid Questions Due	In writing, no later than Monday February 13, 2023 at 2:00 pm to prebid@olivenhain.com
Bid Due Date	Thursday, February 23, 2023 at 2 p.m. Bids due to OMWD Headquarters: 1966 Olivenhain Rd., Encinitas, CA 92024
Engineer's Estimate (Schedule A & B)	\$135,000






Pre-Bid Meeting Sign-In Sheet

Olivenhain Municipal Water District (OMWD) AC and Concrete Paving Maintenance & SWPPP Drainage Improvement Project February 2, 2023


Name	Title	Company	Phone	Email
Rudy Gutier	Est Mator eZ		19-427-8322 Do 80 Valooc	Franknson paving @ yaboocom
Josh- 12 1-12	Vice President			rufo@ Kidk pawing us
JOHN DUKE IR	BEPT. HEAD	ALIGUS ASPHANTIAC	619-562-8201	Idokeire angus as PHAIT. COM
Jonge Mendoza	V . 1	LCVR earthwork	asi 934 3231	Jonge (E) LCNearthwon Kengineening .con
Rubén	President	RAC Count = Engineering	760 497 6663	r claudio @ racconstruction. Wiz
NOYMAN futicirez	Njnyo 3 moore technician	Ninyo & moore	(6/9/990-2232	ngutienez@ninypandmoore.com
Steve Weddle		omwd	760.753.	prebid @ olivenhain. com
Diama Spence Andrea Scot	k Dept. Admin Engk Tech III	Omwo	760.753.6466	
Makuin	Facilities Connaination	omwo	760.753.6466	. 1.

PAVING MAINTENANCE & SWPPP DRAINAGE IMRPOVEMENT PROJECT **EXHIBIT 2 - UPPER PARKING LOT - REV 1 CONTRACTOR TO DEMO APPROXIMATELY 20 FT** OF EXISTING WALKWAY TO CONSTRUCTION JOINT. CONTRACTOR TO **DEMO 3 BALLARDS FOR INSTALLATION OF NEW CONCRETE WALKWAY** PER EXHIBIT 7, DETAIL 1. GATED ACCESS 55 FT 34'\X 16' 42' X 19' 22' X 11' NEW 6" CONCRETE CURB. PER LIMITS OF CRACK SEAL, TYPE I 3" GRIND ASPHALT PATCH SDRSD G-01. SLURRY SEAL, AND RESTRIPING LIMIT OF NEW ASPHALT PAVEMENT NEW CONCRETE WALKWAY PER EXHIBIT 6 DETAIL 4. SLURRY SEAL TO BE LIMIT OF NEW AC CURB EXHIBIT 7, DETAIL 1. APPLIED TO NEW ASPHALT.


PAVING MAINTENANCE & SWPPP DRAINAGE IMRPOVEMENT PROJECT EXHIBIT 4 - HEAVY EQUIPMENT YARD - REV 1



PAVING MAINTENANCE & SWPPP DRAINAGE IMRPOVEMENT PROJECT EXHIBIT 6 - DETAILS




1) CONCRETE WHEEL STOP



DIMENSION (INCHES)						
	Α	В	С			
UPPER LOT	4	-	8			
HEAVY EQ.	4	-	12			






- 1. CONTROL JOINTS SHALL BE SAWCUT WITHIN 8 HOURS AFTER CONCRETE PLACEMENT.
- 2. CONTROL JOINT SPACING AT 9' MAX UNO ON PLAN.
- 3. KEYED JOINTS SHALL BE SDRSD G-10.
- 4. CONCRETE SHALL BE PER SPEC 03000.




CONCRETE PAD




NOTE:

PAINT EDGE OF EXISTING ASPHALT WITH TACK COAT PRIOR TO PAVING. CRACK SEAL JOINT AFTER PAVING OPERATION HAS BEEN COMPLETED.






(3) CONCRETE MOW CURB



PAVING MAINTENANCE & SWPPP DRAINAGE IMRPOVEMENT PROJECT EXHIBIT 7 - DETAILS II



NOTES:

- 1. CONTRACTOR TO FIELD COORDINATE WITH OWNER AND TIE NEW CONCRETE WALKWAY INTO EXISTING CONCRETE WALKWAY AT EXISTING CONTROL JOINT.
- 2. CONTRACTOR TO PROTECT EXISTING SEWER CLEANOUT IN PLACE. PROVIDE CAST IRON SEWER CLEANOUT COVER WITH PICK HOLE.
- 3. CONTRACTOR TO PROVIDE 1.5" BLOCKOUT IN CURB FOR DRAINAGE AT PCR.
 - MODIFIED CONCRETE WALKWAY-UPPER PARKING LOT (NTS)