



Municipal Water District

**ADDENDUM NO. 2
TO THE**

**Manchester Avenue Potable Water Pipeline Replacement Project
for Olivenhain Municipal Water District**

June 22, 2021

The following addendum shall be made part of the Bidding Opportunity. **The deadline for submitting proposals REMAINS UNCHANGED at 2:00 p.m. Thursday June 24, 2021 at 1966 Olivenhain Road, Encinitas, CA 92024.**

ADDENDUM SECTION 1 – BIDDING QUESTIONS

1. Q: Please confirm that the Paving Contractor is to use C1-PG64-10 Asphalt for Public Streets and C2-PG64-10 for Private Streets since C1-PG64-28M isn't noted on the Drawings.
A: Contractor shall use C1-PG 64-28M for all finishing course trench restoration in the public right-of-way per Contract Documents and City standards. See additional paving information in the Pre-Bid Meeting Minutes.
2. Q: Page 228 of the Contract Document Section 2.4 "Pavement Reinforcement Membrane" shall be per City of Encinitas Standards. Could you provide the Standard Drawing Number or Spec on this item?
A: See Appendix A of the Contract Documents.

END OF ADDENDUM NO. 2

Attachments: None

APPROVED:

OLIVENHAIN MUNICIPAL WATER DISTRICT



Jason P. Hubbard, P.E.
Engineering Manager